

Kigali, on..... **24 DEC 2021**

No.11.07.053/3234/21-22/PROC-DSS-CEO/GU/rjp

ADDENDUM No. 1

Subject: Extension of bids submission deadline and response to the requested clarifications on the tender No.11.07.053/3493/G/NCB/21-22/PROC-DSS-CEO/GU/ES related to the acquisition of commercial meters

Reference is made to the issued bidding document No.11.07.053/3493/G/NCB/21-22/PROC-DSS-CEO/GU/ES related to the acquisition of commercial meters;

Reference is also made to the letters from a prospective bidders that requested for clarifications on the specifications for the above tender and an extension of bids submission deadline in order to submit responsive bids:

After analyzing the requests, WASAC would like to inform all prospective bidders the following:


1. The characteristics mentioned in table below will be considered for all bids:

No.	Diameter	DN 32 (11/2 ")	DN40(2")
1	Measuring range R= Q3/Q1	R160	R160
2	Maximum flow-rate Q4	12.5m3/h	40m3/h
3	Nominal flow-rate Q3	10m3/h	15m3/h
4	Transitional flow-rate Q2	100l/h	160l/h

2. Only meters with rotating register will be accepted. Even if the meter is in brass composition, this register part may be made in hard plastic material;
3. The multi jets types are accepted as stated in our technical specifications;
4. About the requested sample, if a manufacturer of DN32 & DN40 is one, every bidder can provide one sample either for DN32 or DN 40;
5. The deadline for submission of bids initially scheduled on 30/12/2021 at 10:30 am (local time) is extended to Friday 14th January 2022 at ~~10:30~~ am (local time).

Note that other bidding document terms and conditions remain unchanged.

Sincerely,



Gisele UMUHUMUZA
Acting Chief Executive Officer